



October 3, 2024

**SUBJECT:** Request for Proposals 2024-026, *Mental Health Pod Renovation JIC*

**MESSAGE:** Please note and acknowledge the following changes or additions to be included in the referenced section(s) of 2024-026.

1. Including “MES Design Narrative - Addendum #2” received from the architect in response to the RFI we received on September 27, 2024. The full RFI text can be found below.

“In both buildings, according to the architectural drawings, partition walls will be added in the open area and a deputy station will be built. Electrical drawings do not show power for those walls. Please clarify.”

Please complete the acknowledgement of this notice on the next page of this document and include it in your proposal response.

Sincerely,

William V. Spinelli, CPA  
Chief Financial Officer

WVS/ref

Enclosure



**CHAD CHRONISTER, SHERIFF**

ACKNOWLEDGMENT OF AMENDMENT

We do hereby acknowledge the information and/or changes described in  
Amendment #2 to Request for Proposals 2024-026, *Mental Health Pod Renovation JIC*

PLEASE PRINT: Company Name: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_

***Signature:*** \_\_\_\_\_

(Signed Acknowledgment must be included with your Submission)



October 1, 2024

Emily Breheny  
The Lunz Group  
58 Lake Morton Drive  
Lakeland, FL 33801  
Phone: (863) 682-1882

**RE:** HCSO Mental Health Clinic, MES Project # 2024514

**Subject:** JIC & JID Addendum #2 dated 10-04-2024

Emily Breheny,

Listed below is the design narrative for additions per Addendum #2 concerning the aforementioned project:

**ELECTRICAL SCOPE:**

1. Remove existing receptacle outlets on half partition walls in open bed area to source. Maintain existing breakers made spare for new circuits.
2. Provide (1) duplex outlet per bed.
3. Provide an (6) homeruns for the bed area utilizing existing breakers made spare from demolition.
4. Provide (1) homerun for new Deputy Station.
5. Provide (3) duplex receptacles, (2) data outlets, and (1) TV outlet for new Deputy Station.
6. Provide (1) duplex receptacle and (1) data outlet for new Deputy desk.

Sincerely,

Jason Brown  
Senior Electrical Designer