

May 13, 2016

REQUEST FOR PROPOSAL 18-16
QUESTION & ANSWER #2

Q #1 We would like to confirm the building and foundations should be designed for an Exposure C category.

A #1 Correct

Q#2 We would like to confirm the risk category for the building is classified as IV-emergency vehicle storage, police stations, etc.

A #2 The building is for storage only. In any emergency situation, equipment would be relocated.

Q#3 For pricing the appropriate power supply, is any information readily available from the current documents detailing the power riser on site?

A #3 The electrical service entrance panel is located off the NW corner of the proposed building as shown in drawing E-101, view # C1 as detailed on sheet E-502.

Q#4 Reference Title Sheet, Index of Drawings, Survey V-100 existing conditions (1 of 1), V101 existing conditions (2 of 2). These drawings are not included in the bid set. Please provide these drawings or an existing topographic survey that indicates existing grades.

A #4 These drawings are from before the existing site work was completed. V100-V101 are attached for your review but offer no current information.

Q#5 Manufacturer's submitted for approval:

A#5 Star Buildings – Approved
Whirlwind Steel – Approved
A & S Building Systems – Approved

Q# 6 Will construction permits be required?

A #6 Yes

Note: Retention pond is to the south of the proposed building. Roof pitches, downspouts etc should be directed southward.