

**Questions & Answers**  
**#8**

- 1. Inquiry regarding the type of walls to be used. In A110, there are walls that has no label. We'd like to request a complete copy of the schedule.**

**Answer:** *Per Note 3 on A-110, all walls are S4A unless noted otherwise. Walls missing labels are S4A.*

- 2. It was mentioned at the pre-bid meeting that the drywall at the exterior walls should be removed & replaced. The plans do not indicate this. Please confirm. Is the existing framing & insulation to remain?**

**Answer:** *Note 2 on AD-101 is typical of all exterior walls. "Remove existing gypsum board and furring at exterior walls."*

- 3. The RFP mentions wet & ink signatures. Are electronic signatures acceptable for online submissions?**

**Answer:** *Electronic Signatures are acceptable for online submissions.*