

Questions & Answers #4

1. Sheet E-202 fixture schedule shows A, D,S x1, but there is a section gym 179 there all B fixtures but no information on the B fixtures. What is the spec on the B fixture?

Answer: SP4D LLP 4FT MSL4 80CRU 35K 1500LMF DBW SCT MIN10 FLL MVOLT
FINISH ZT F2/36A RDCY

2. Sheet E-401 in storage 167 there is two different styles A fixtures. What is the difference?

Answer: There is only one type of fixture. Air terminals have been laid over top of lighting.
Coordinate correct location for air terminals.