



OFFICE OF THE SHERIFF

Chad Chronister, Sheriff
Donna Luszczynski, Chief Deputy
Hillsborough County, Florida

June 29, 2018

SUBJECT: Amendment No. 3 to RFP 7-18 Bulk Fuel Site Preparation & Tank Installation

MESSAGE: Please note and acknowledge the following changes or additions to be included in RFP 7-18:

1. Technical Specifications (Part C)(1)(c) - Replace in its entirety as follows:
 - c. Place and finish a rebar-reinforced concrete slab.
 - 1) Required Services: An eight (8) inch thick, above ground, concrete slab measuring 36' x 16' for the fuel tank. The slab shall be positioned northeast to southwest on the property.
 - 2) Optional Services: An eight (8) inch thick, ground level, concrete slab consisting of number five (5) rebar on one (1) foot centers, measuring 32' x 14' to provide parking for vehicles while fueling. The slab shall be positioned perpendicular and centered against the fuel tank slabs seen in Exhibit A.
2. Replace Exhibit A in its entirety, see attached.

NOTE: Optional Services shall be considered as a separate line item on the Proposal Response (Part D), and will be awarded only if budget permits.

Please note that this document hereby becomes a part of Bid 7-18 and without this document, the Bid is considered incomplete.

Sincerely,

A handwritten signature in blue ink, appearing to read "Christina R. Porter".

Christina R. Porter, CPA
Chief Financial Officer

CRP/cbc

Enclosure

ACKNOWLEDGEMENT OF AMENDMENT

We do hereby acknowledge the information and/or changes described in the
Amendment No. 3 to Bid 7-18.

PLEASE PRINT – Company Name: _____

By: _____

Title: _____

Date: _____

Signature: _____

(Signed Acknowledgement must be included with your Bid Package)

EXHIBIT A

