



# OFFICE OF THE SHERIFF

---

**Chad Chronister, Sheriff**  
**Donna Luszczynski, Chief Deputy**  
*Hillsborough County, Florida*

May 15, 2018

**SUBJECT:** Amendment No. 2 to RFP 13-18 Sheriff's Operations Center Chiller Upgrade

**MESSAGE:** Please note and acknowledge the following changes or additions to be included in the referenced section(s) of RFP 13-18:

1. Technical Specifications, (Part C)(2) – Replace paragraph (d.) as follows:

d. Equipment and Controls

The Contractor shall be responsible, either through his own capabilities or that of an electrical subcontractor, for any electrical re-connections required as part of the Work to replace the cooling tower, water cooled chillers and any affected equipment, as well as to the existing building automation controls which will be re-used. The Alerton Control System from CSSI will require upgraded circuit boards to support the new equipment. Additionally, a BAC Net integration card shall be provided by the Contractor.

HCSO requires a Factory authorized start-up of all new equipment and a Certified, Independent Test and Balance of equipment performance and water flows upon completion.

Please note that this document hereby becomes a part of RFP No. 13-18 and without this document, the Proposal is considered incomplete.

Sincerely,

A handwritten signature in blue ink, appearing to read "Christina R. Porter".

Christina R. Porter, CPA  
Chief Financial Officer

CRP/dmj

Enclosure

ACKNOWLEDGEMENT OF AMENDMENT

We do hereby acknowledge the information and/or changes described in the  
Amendment No. 2 to RFP 13-18.

PLEASE PRINT – Company Name: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_

*Signature:* \_\_\_\_\_

(Signed Acknowledgement must be included with your Bid Package)