

**HILLSBOROUGH COUNTY SHERIFF'S OFFICE  
FINANCIAL SERVICES DIVISION  
PURCHASING UNIT  
QUESTIONS AND ANSWERS FOR  
RFP NO. 13-18 Sheriff's Operations Center Chiller Upgrade**

**Question#1:** *The specification calls for connecting the new chiller via BACnet to the existing building automation controls. What brand of building automation exists at the facility at 2008 East 8<sup>th</sup> Avenue, Tampa?*

**Answer #1:** The existing control systems in this building are Alerton from CSSI.