

Questions & Answers
#1

1. Bidder request Garage Keepers Liability requirement (Agreement page 4) be removed as it is not applicable to this work

Answer: These insurance requirements are only required when in performance of the contract employees or subcontractors from the awarded vendor will need to come onto HCSO property. In Summary: Garage keepers insurance is only required if the contract covers that type of work being performed. i.e a body shop doing vehicle repairs.

2. Please confirm that Davis Bacon Wages apply, and the applicable determinations: FL20240208 & FL20240116.

Answer: Davis Bacon Wages does not apply to this solicitation. This Bid is not federally funded, nor is it construction.

3. Please confirm, bidders are to submit a hard copy package, as well as the zip file via email, prior to the deadline?

Answer: Yes, the requirements of 2024-013 1.4 *Bid Submission Requirements* include one original hard copy and one zip file via email prior to the deadline.

4. Who is to supply the filters for the HVAC units on the project? The bidder, or will they be supplied by Hillsborough County Sheriff's Office?

Answer: HCSO will supply and maintain filters for the HCSO Crime Scene Unit location only. The Awarded Supplier is to provide necessary filters for the service schedule outlined for Service type groups A, B, & D as described in 2.4.4.

5. Who is to supply the granulated rubber for the traps?

Answer: Removed granulated rubber may be cleaned and returned while being supplemented with new or it may be replaced in its entirety by the Awarded Supplier.

6. 2.3.3 states that "The shoot tank room will need a lead removal wipe down and vacuuming of all surfaces." Will this include ceilings, cabinets, furnishings, etc.? Everything in the room?

Answer: Yes. With regard to the Occupational Safety and Health Administration (OSHA) Lead Standard (29 CFR 1910.1025) HCSO requires floors, and any surfaces personnel may come into contact with be cleaned of lead particles on a scheduled frequency as described.