

May 13, 2016

REQUEST FOR PROPOSAL 18-16
QUESTION & ANSWER #3

Q #1 Will the building have fire sprinklers?

A #1 No.

Q #2 What is the Code base use/what will the building be used for?

A #1 A garage for parking boats

Q #3 How do we handle Handicap access with the existing grades.

A #1 I don't believe this an an issue. We have no ADA deputies and this building will not be for public access. The adjacent office building is ADA accessible.

Q#4 Is additional parking required for this building?

A #1 No.

Q#5 Do we energize electrical sub panel? If we do where does it come from?

A#5 From existing service panel on site.

Q#6 The City of Tampa requires an additional 6" of free board for finish floor flood elevations, which would put the finish floor at NSVD 10.5 feet?

A#5 This is not occupied space. This is boat storage.